

STV SEELYE STEVENSON VALUE & KNECHT.

ENGINEERS & PLANNERS.

99 PARK AVENUE
NEW YORK, NY, 10016
212/867-4000, Telex 64 9081 SSV&K

December 22, 1983

New York City Department of Environmental Protection
Bureau of Sewers - Division of Sewer Regulation
and Control
40 Worth Street
New York City, NY 10013

Attention: Mr. R. Agarawai:

Reference: Amtrak North Access Connection
Tenth Avenue Tunnel

Subject: Meeting Minutes

SSV&K No.: 22-6018

Dear Sir:

Enclosed please find the minutes of the N.Y.C.D.O.T., M.T.C.C.C.
meeting of Monday, December 19, 1983.

Very truly yours,

STV/SEELYE STEVENSON VALUE & KNECHT.


James P. Hynes, P.E.
Project Manager

JRB:mbm

Enclosures:
Minutes of Meeting 12/19/83

Copies to:

H.F. Longhelt - Amtrak
A. Shaw - Amtrak
P. Henry - Amtrak
R. Sturm - LIRR
R.J. Posthauer - SSV&K
J. Aliprantis - SSV&K
J.R. Brusko - SSV&K
Central File (2)
File/JPH



STV ENGINEERS, Engineers, Architects, Planners, Construction Managers. Professional Member Firms:
STV/Baltimore Transportation Associates; STV/Lyon Associates; STV/Management Consultants Group; STV/
H. D. Nottingham & Associates; STV/Sanders & Thomas; STV/Santafric; STV/Seelye Stevenson Value & Knecht.

STV/SEELYE STEVENSON VALUE & KNECHT

Amtrak North Access Connection

Tenth Avenue Tunnel

SSV&K No.: 22-6018

Minutes:

December 19, 1983

Time: 10:00 A.M.

Place: N.Y.C.D.O.T., M.T.C.C.C.
51 Chamber Street
New York, NY 10013

Attendance: R. Lawrie - N.Y.C.D.O.T., M.T.C.C.C.
H. Kamamis - N.Y.C.D.O.T., M.T.C.C.C.
R. Aggarawai - N.Y.C.D.E.P., Sewers
P. Jain - N.Y.C.D.E.P., Water
J. Brusko - SSV&K

Discussion:

1. Bureau of Sewers has submitted its comments with letter of November 23, 1983 (Received by SSV&K on November 28, 1983). SSV&K is addressing these comments and will formally resubmit to Bureau of Sewers very shortly.
2. Local Community Board, Fire Department, and Police Department have "signed-off" on the 95% submission.
3. Division of Design - Bridges will be forwarding a letter advising that sidewalk replacement over open cut will require steel reinforcement.
4. Bureau of Water Supply requested that 12" Ø D.I.P. water main on east side of Tenth Avenue be shifted in an easterly direction to avoid its being located above the 36" Ø steel pipe water main. All pipe in the 12" Ø D.I.P. water main shall be restrained joint D.I.P. SSV&K will comply.