

CITY OF NEW YORK
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF SEWERS
INTER-DEPARTMENT
MEMORANDUM

DATE: November 23, 1983

TO: MAGDI FARAG, P.E., CHIEF, ENGINEERING REVIEW SECTION
FROM: GORDON YEE, P.E., ACTING CHIEF, PRIVATE DRAINAGE REVIEW SECTION
SUBJECT: NORTH ACCESS CONNECTION, 10TH AVENUE AMTRAK TUNNEL, MTA #1-02-21064-0-0
BOROUGH OF MANHATTAN

This is in reply to your transmittal of plans for the replacement of an existing 4'-0" x 2'-8" combined sewer with a new proposed 30" R.C.P. sewer in 10th Avenue south of W.32nd Street, with a memo dated November 17, 1983.


Our review of the subject proposal indicates that the proposed 30" R.C.P. sewer section is adequate to accept the computed flow of 30.7 c.f.s. from the contributory area of 6.5 acres, since the proposed sewer's capacity will be 37.0 c.f.s.
Therefore we have no objection to this proposal.


GORDON YEE, P.E.,

ENCLOSURE

cc: Novotny
Yee
Swedlow (2)
Suspense

MS:im



CITY OF NEW YORK
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF SEWERS
INTER - DEPARTMENT
MEMORANDUM

November 17, 1983

TO: GORDON YEE, P.E., ACTING CHIEF, PRIVATE DRAINAGE REVIEW SECTION
FROM: MAGDI FARAG, P.E., CHIEF, ENGINEERING REVIEW SECTION
SUBJECT: NORTH ACCESS CONNECTION, 10TH AVENUE TUNNEL AMTRAK, BOROUGH OF MANHATTAN

Seelye Stevenson & Knecht, Engineers and Planners, have submitted plans with a letter dated November 10, 1983 for the above referenced project. The plans show replacement of a portion of existing 4'-0" X 2'-8" brick egg shaped sewer in 10th Avenue with a 30" R.C.P. class III sewer.

Enclosed is a set of plans and hydraulic computations. Please check if the proposed sewer has the same capacity as the existing sewer and relate your comments to this office as early as possible so that we can process the review of this project.

ENCLOSURE.

Magdi Farag / RA
MAGDI FARAG, P.E., CHIEF
Engineering Review Section

cc: Novotny
Farag
Aggarwal
Suspense
RA:lp