

FIRE SERVICE INCORPORATED

54151

SUBSIDIARY OF FIRECOM INC.

39-27 FIFTY NINTH STREET
WOODSIDE, NEW YORK 11377
(718) 899-2311

REPORT OF FIELD SERVICE

OFFICE TO

SERVED

7 World Trade Center
N.Y.C.

AUTHORIZED BY MR. R. T. King		CONTRACT #	FEE SERVICE #	FJ #	FO #	SEE AT JOB SITE
DATE SCHEDULED 5/11/98	EXT	TIME SCHEDULED 10:00 AM	SERVICE #		ASSIGNED F. ARK	

MATERIAL RECORD

QUANTITY ISSUED	QUANTITY B/O	FCI NO	DESCRIPTION	UNIT PRICE	PER	TOTAL AMOUNT

CK APPROPRIATE BOX

- Q.C. ☐ EMERGENCY CALL
I&T ☐ CONTRACT CALL
FEE CALL ☐ PICK UP
DELIVERY ☐ DEMO OWNER
DEMO ☐ SURVEY

DEPARTED SHOP	TIME IN	TIME OUT	RETURNED SHOP	TOTAL HOURS	START MILEAGE	END MILEAGE	MISC EXPENSE	CAR FARE
2:00	3:30	5:00	6:00					
☐ MAT REQD ☐ PARTIAL ☐ OTHER ☐ LABOR REQD				SERVICE DATE 5/11/98		CUSTOMER SIGNATURE [Signature]		
I&T COMPLETE ☐		CALL COMPLETE ☐		WILL RETURN ON		SERVICE MAN SIGNATURE [Signature]		

AUTHORIZATION FOR FIRE ALARM INTERRUPTION
 The undersigned has been advised by Fire Service, Inc. representative that it may be necessary to interrupt the fire protection service by disconnecting the system and/or a component in the performance of their assigned work. The undersigned hereby assumes the responsibility for the notification of the authorities at the time the interruption is initiated and will take all of the precautions deemed necessary during the period of interruption and hold harmless Fire Service, Inc. and its employees regarding interruption of the protection service during their service of the equipment.

PROBLEM—AS DESCRIBED

Trouble with FIRE Alarm
NO RESET.

SERVICE PERFORMED Found system going in and out of alarm due to a combination smoke Det on the 3rd FL. M.E.R. which was going in and out as F.S.D. Reset because steam building up in the E.M.R. Therefore, A.S. Recommended & did. B.S. Bldg. Took Head off & kept out until steam cleared from room.

WORK REMAINING Replace or put back smoke Det Head once steam is clear inside M.E.R.



FIRE DEPARTMENT

BUREAU OF FIRE PREVENTION

U168689

VIOLATION ORDER

Violations to which this order is issued are those violations of the Fire Department Code of the City of New York which are indicated by the letter "V" in the left column of the list of violations. Where there is a choice of violations, the applicable one is indicated by the letter "V" in the right column of the list of violations.

To: 7 WOOD ST. TRUCK COMPANY OFFICE 5 BRIDGE PLAZA PRO.
 Address of Premises Boro Name of Owner, Lessee, Occupant, etc.
Room No. or Floor Office 5 BRIDGE PLAZA PRO.
 Room No. or Floor Name of Occupant Account No.

Item No.	Item No.	VIOLATION ORDER
FP-1-2	Provide / Retill (or) recharge	approved fire extinguishers at
FP-3-4	Provide / Retill (or) recharge	approved fire extinguishers at
FP-7	Provide	properly covered fireproof receptacles for inflammable rubbish at
FP-11	Provide	properly covered fireproof receptacles for inflammable rubbish at
FP-12	Remove	all accumulations of inflammable rubbish from premises and maintain all parts of premises free from such accumulations at all times (Comply FORTHWITH)
FP-13	Reduce	height of stock to not less than 18 inches of ceiling or sprinkler or
FP-15	Discontinue	storage, sale, or use of volatile flammable liquids.
FP-17	Discontinue	use of open flame or
FP-21	Maintain	floors clean of waste oils.
FP-25-26	Provide	Exit signs/Red lights over exit signs of
FP-27	Maintain	adequate aisle space not less than 36 inches at
FP-28	Remove	all obstructions to means of egress at
FP-30	Remove	grease, paint, or other accumulations from hoods or ducts on
FP-42	Replace	missing or defective hose on standpipe outlet at
FP-56	Remove	all obstructions to sprinkler control valve at
FP-60	Seal	sprinkler control valves "open" with approved seals at
FP-102	Remove	unapproved iron bars, grills, gates, or other obstructing devices on any window giving access to fire escapes or to a required secondary means of egress.
SP-12	Arrange	(scuttle/bulkhead door) to be readily opened from the inside without the use of a key.
SP-15, 16, 17, & 18	Provide	that door of (public hall/dumbwaiter/roof bulkhead/rubbish chute/laundry chute hopper/kitchen/incinerator chute hopper/garage/garage vestibule/stairway/store room/rubbish room/incinerator room/boiler room/maintenance room) located at be self closing/placed in good operating condition/maintained closed.
SP-19	Maintain	adequate light in (public hallway/public stairway) at
SP-34	Properly	scrape and paint with two coats of paint the (fire escape/ exterior screened stairway) on (front/rear/ side) of building.
SP-35	Properly	replace all defective portions of the (fire escape/ exterior screened stairway) at the side of the building. All windows and doors which open upon the course of the (fire escape/ exterior screened stairway) are to be repaired and all work showing corrosion is to be scraped and painted with at least two coats of paint.
SP-38	Provide	that the self-closing (door/window) opening on the course of the (fire escape/ exterior screened stairway) on the side of the building on the story, be (placed in good operating condition/maintained closed).
SP-39	Provide	that the door serving as required means of egress at be readily openable from (the inside/both sides) without the use of a key.
SP-42	Store	(paint/paint drop cloths) in approved storage (area/room/cabinet) at
SP-53	Replace	(used/damaged/missing) sprinkler head at
SP-64	Discontinue	use of temporary wiring being used in place of fixed wiring at
SP-80	Properly	store (mattresses/furniture/paints/insecticides) in approved storage (compartment/room) at
SP-81	Provide	temporary protection of unused dumbwaiter shafts by means of nailing doors closed and sealing of unprotected openings on all floors, including cellar, (skylights shall remain) pending compliance with the requirement of the Department of Buildings.
FO-5	Provide	an affidavit from a licensed fuel oil installer that oil burner is clean and in operating condition.
SP100	SP100	Provide Fire Guard with a Certificate of Fitness for each seven (7) Floor or part thereof to be on duty to make hourly rounds.
SP101	SP101	Maintain Records of Fire guard's hourly inspections and make these Records available for F.D. Review.

If this order has not been complied with by the days of the issuance date (or forthwith for those violations designated "comply FORTHWITH"), a summons will be served for violation of Chapter 19 of the Administration Code of the City of New York.

This is to certify that I have made an inspection of said premises and have issued the above order to

Mr. T. GALEWIN

Name of person who received this order

Owner/Agent/Occupant

Inspector

Date

Important: See instructions on reverse side.

For information inspection or dismissal contact inspection unit:

Unit E-10

Unit Address 124 Liberty St.

Unit Telephone 212/510-4216

Forth With

TIME: 1:26 PM

Thomas Vagesser
 Fire Commissioner

5/17/98

U 168689



VIOLATION ORDER

VIOLATION ORDER

To: 740247 TRHWA...
Address of Premises
Boro
Name of Owner, Lessee, Occupant, etc.

Address of Premises 1700 Room No. or Floor 1700

City San Francisco Type of Occupancy Office

State California Name of Owner, Lessee, Occupant, etc. Office

County San Francisco Account No. 1700

VIOLATION ORDER

Item No.	Item No.	Violation Order
FP-1-2	Provide / Refill (or) recharge approved _____ fire extinguishers at _____	
FP-3-4	Provide / Refill (or) recharge approved _____ fire extinguishers at _____	
FP-7	Provide properly covered fireproof receptacles for inflammable rubbish at _____	
FP-11	Provide _____	
FP-12	Remove all accumulations of inflammable rubbish from _____ and maintain all parts of premises free from such accumulations at all times (Comply FORTHWITH)	
FP-13	Reduce height of stock to not less than 18 inches of ceiling or sprinklers at _____	
FP-15	Discontinue storage, sale, or use of volatile flammable liquids.	
FP-17	Discontinue use of open flame or _____	
FP-21	Maintain floors clean of waste oils.	
FP-25-26	Provide _____	
FP-27	Maintain adequate aisle space not less than 36 inches at _____	
FP-28	Remove all obstructions to means of egress at _____	
FP-30	Remove grease, paint, or other accumulations from hoods or ducts on _____	
FP-42	Replace missing or defective hose on standpipe outlet at _____	
FP-56	Remove all obstructions to sprinkler control valve at _____	
FP-60	Seal sprinkler control valves "open" with approved seals at _____	
FP-102	Remove unapproved iron bars, grills, gates, or other obstructing devices on any window giving access to fire escapes or to a required secondary means of egress.	
SP-12	Arrange (scuttle/bulkhead door) to be readily opened from the inside without the use of a key.	
SP-15, 16, 17, & 18	Provide that door of (public hall/dumbwaiter/roof bulkhead/rubbish chute/laundry chute hopper/kitchen/incinerator chute hopper/garage/garage vestibule/stairway/store room/rubbish room/incinerator room/boiler room/maintenance room) located at _____ be self closing/placed in good operating condition/maintained closed.	
SP-19	Maintain adequate light in (public hallway/public stairway) at _____	
SP-34	Properly scrape and paint with two coats of paint the (fire escape/exterior screened stairway) on (front/rear/ _____ side) of building.	
SP-35	Properly replace all defective portions of the (fire escape/exterior screened stairway) at the _____ side of the building. All windows and doors which open upon the course of the (fire escape/exterior screened stairway) are to be repaired and all work showing corrosion is to be scraped and painted with at least two coats of paint.	
SP-38	Provide that the self-closing (door/window) opening on the course of the (fire escape/exterior screened stairway) on the _____ side of the building on the _____ story, be (placed in good operating condition/maintained closed).	
SP-39	Provide that the door serving as required means of egress at _____ be readily openable from (the inside/both sides) without the use of a key.	
SP-42	Store (paint/paint drop cloths) in approved storage (area/room/cabinet) at _____	
SP-53	Replace (used/damaged/missing) sprinkler head at _____	
SP-64	Discontinue use of temporary wiring being used in place of fixed wiring at _____	
SP-80	Properly store (mattresses/furniture/paints/insecticides) in approved storage (compartment/room) at _____	
SP-81	Provide temporary protection of unused dumbwaiter shafts by means of nailing doors closed and sealing of unprotected openings on all floors, including cellar, (skylights shall remain) pending compliance with the requirement of the Department of Buildings.	
FO-5	Provide an affidavit from a licensed fuel oil installer that oil burner is clean and in operating condition.	
0100 SP 100	Provide Fire Guard with a Certificate of Fitness for each floor (7) Floor or part thereof to be on duty to make hourly rounds.	
0101 SP 101	Maintain records of Fire guard's hourly inspections and make these records available for F.D. Review.	

If this order has not been complied with FOURTEEN days of the issuance date (or forthwith for those violations designated "comply FORTHWITH"), a summons will be served for violation of Chapter 19 of the Administration Code of the City of New York.

This is to certify that I have made an inspection of said premises and have issued the above order: To

Mr. T. G. Galt

Name of person who received this order

Owner / Agent / Occupant

Introduction

100

Important: See instructions on reverse side

For information, inspection or dismissal, contact inspection unit

Unit E-10

Unit Address 177 Liberty St.

Unit Telephone 04043 10-7042