

MAY 27 1998 1:29PM

SWANKE HAYDEN CONNELL ARCHITECTS INK GROUP

NO. 0371 25 6/12 1/3



CS THE CANTOR SEINUK GROUP, P.C. CONSULTING ENGINEERS
 600 MADISON AVENUE
 NEW YORK, NY 10022

Fax Cover Sheet

DATE: 5.13.98

TO: JUAN MEJIA

PHONE:
FAX: 219-0059


JOE ALIOTTA

PHONE:
FAX:PHONE:
FAX:

FROM: ANCA BARON

PHONE: 755-4242
FAX: 752-6924

RE: OEM



Number of pages including cover sheet:

3

Message

For the hurricane wall — use 8 SSW 14 @ 12" o.c. top.
 and at corner 10 SSW ¹² @ 12" o.c.

This wall will take press. of 240 psf & 420 psf at
 corner → from 155 mph wind speed.

Connections at top & bottom w/ 1/2" @ ea. stud (12" o.c.)
 w/ 1/2" exp. bolts into slab — at top & to have slotted
 holes so the stud does not take any axial force.