

MTA. March 10, 1998

- DOT shall pull cables? CO-AX? DOT does not have enough familiarity, but can be done.

MTG. March 19, 1998 @ 1 WTC 51st Fl

Agenda: Emergency F.O. tank (8,000 gal)

- 1) Fire rating - 3HR rating (flush joints, max. 250°F oil)
SHC will do type of oil
 - 2) Structural - will be provided in final dwg's
 - 3) Location of tank (6,000 gal) SHC to send to PA a letter of explanation, to justify location (by Monday).
PA to respond in 1 week.
(Battery operated crane)
- ** Notify PA with (5)^{to} days in advance, in order to have a "review by appointment" date.