

SWANKE HAYDEN CONNELL ARCHITECTS

Memorandum

Project Name and Address:		Project No:
Mayor's Office of Emergency Management		5576A
7 World Trade Center		Project Director/Manager:
New York, New York		Meinhardt/Aliotta
		Client:
		Silverstein Properties, Inc./ DCAS/DRES/ MOEM
		Subject:
		Outstanding Equipment Information
To	From	Date Prepared
Jerome M. Hauer-MOEM	Joseph J. Aliotta	February 26, 1998

The following is a summary of equipment product data outstanding as of 02-25-98 which impacts the critical path of the project schedule:

LAN Room

OEM Required Information:

1. Catalog cuts for all computer equipment including BTU output.
2. Bell Atlantic catalog cuts for all equipment including power requirements and BTU output. OEM/DolTT is working with Bell Atlantic to obtain this information.

Motorola Required Information:

1. Radio rack equipment lay-out.
2. Catalog cuts for all equipment including power requirements and BTU output.

Due to the combined use of this room involving radio, computer LAN, telephone and audio-visual equipment, SHCA and its consultants have not been able to layout the equipment for this room and make the final determination of power & HVAC requirements for this room. Please note that the OEM team has met regularly with the SHCA team and the vendors. They are putting their best efforts forward to obtain the information, however, it is not coming together in time to meet the schedule.

EOC

OEM Required Information:

1. Specific catalog cuts or written specifications for all departmental computer and radio equipment other than the standard OEM equipment (PC with monitor, a radio head, telephone & back-up telephone and 13" TV monitor) including equipment sizes, power, BTU output, cabling & connections and audio-visual connectivity and compatibility if required. SHCA is aware of FDNY & NYPD equipment in general terms but not specifics. OEM has not indicated any other departmental equipment needs (i.e. - additional phones, radios, PCs, monitors, etc.).

Other Motorola Required Information:

1. Equipment outlet locations for the Rooftop Radio Room.
2. Equipment outlet locations for the Watch Command Equipment Room.
3. Additional structural information previously requested for the rooftop antennas for review by Cantor/Seinuk.
4. A detailed roof plan indicating all rooftop antennas and microwave dishes must be submitted to Silverstein Properties, Inc. for review and approval by their outside consultant to ensure no conflict with existing antenna/microwave equipment.

If this information is not resolved and issued to the SHCA team by 03-06-98, SHCA cannot commit to the 04-06-98 issue date for Construction Documents per the published 12-12-97 project schedule.

Cc: J. Dominguez-DCAS/DRES

NEWYORK01\PROJECTS\911\DEVELOPMENT\MOEM\MEMO\MOEM MEMO 32-26-98.DOC

Swanke Hayden Connell LLP/Swanke Hayden Connell & Partners LLP
295 Lafayette Street, New York, New York 10012
212 226 9696, Fax 212 219 0059