

JAN 30 1998 2:16PM

SWANKE HAYDEN CONNELL ARCHITECTS

NO. 2636 P. 2/5

**SILVERSTEIN
PROPERTIES**

Silverstein Properties, Inc.
7 World Trade Center
New York, N.Y. 10048
Telephone: 212-619-6569
Fax: 212-732-5190

January 21, 1998

Mr. Joseph Aliotta
SWANKE HAYDEN CONNELL LTD.
295 Lafayette Street
New York, NY 10012

**RE: 7 World Trade Center
23rd Floor
Mayor's Office of Emergency
Management Antenna Layout
Roof Radio Room**

Dear Mr. Aliotta:

As a follow up to our walk-thru of the proposed antenna layout/roof radio room at 7 World Trade Center, please be advised that conduit will not be permitted to be installed through the roof's elevator machine room, however you can use the route through the garage where the window washing rig is housed. Also, the enclosure for the radio equipment room should be of the same material as the existing penthouse machine rooms.

If you have any further questions, please call.

Sincerely,


Walter J. Weems III
Building Manager

WJW/dr

cc: Sal Lifrieri - M.O.E.M.
Cathy Giliberti
Chi Chu
Mark Torre
Charlie Magee

c:\moemrad\wvw