

JAN. 21. 1998 10:44AM

SWANKE HAYDEN CONNELL ARCHITECTS

NO. 2136 P. 1/3

SWANKE HAYDEN CONNELL ARCHITECTS**Fax Message**

Re	Mayor's Office of Emergency Management <i>Emergency Operations Center-7 World Trade Center</i>	From	Joseph J. Aliotta	Pages	3
		Job No.	5576A	Time	10:41AM
		Date	01/21/98 (Wed)		

Distribution: (Please deliver to person(s) indicated by '✓')

Silverstein Properties, Inc. (212) 732-1207	DCAS/DRES (212) 669-3640	OEM (212) 442-8885/9266
✓ Ms. Catherine Giliberti	✓ Mr. Josep Dominguez	O Mr. Jerry McCarty
✓ Mr. Chi Chu (212) 687-0067	O Mr. Vinicius Castagnola	O Mr. Jerome M. Hauer
Essential Technologies (301) 736-1026	Cosentini Associates (212) 615-3700	Shen Milsom (212) 725-0864
O Ms. Merrily Powell	✓ Mr. Michael Maybaum	✓ Mr. Ernest J. Schirmer
	O Mr. Robert Slavik	
BFI (212) 679-2201	RSA (212) 633-1613	SHCA
O Mr. Rob Willard	O Mr. Robert Schwartz	O Mr. Carl Meinhardt
O Mr. Ron Cocuzza		O Mr. John Vande Plasue

Message

Attached please find SM&W letter dated 01/16/98 in reference to the sound isolation for the 7th Floor Emergency Generator Room.

Per the 01/15/98 Project Progress Meeting, C. Chu -Silverstein Properties stated that the landlord requires all tenants to test and perform maintenance on non-business hours. Silverstein also stated that they assume the adjacent tenants will have evacuated under these emergency conditions and moderate noise transmission will not be a problem.

Based upon the direction given at the 01/15/98 meeting, SHCA/SM&W will proceed with the design of standard spring vibration isolation and MER wall construction.

Should you have any questions or comments, please call.

If there are any problems with this transmission, please call (212) 219-6716

Swanke Hayden Connell Ltd.

295 Lafayette Street, New York, New York 10012
(212) 225-9696. Fax (212) 219-0059

\\Newyork01\Projects\5576A\Oemdocs\Fax\Dist Fax 01-22-98.Doc