

May 11, 1998

Mayor's Office of Emergency Management
7 World Trade Center
Manhattan
Project # 96-1346

SECOND REVIEW OF FINAL PLANS
ARCHITECTURAL ISSUES

1. Radio room should have (1) step at the door.
2. Work stations on Vesey Street shall have only (3) duplex outlets each.
3. Details for antenna dishes support shall be incorporated to the drawings.
4. Clarify that no "dog houses" shall be installed on raised floors.
5. Comments on Furniture Manifest List received on May 8, 1998, will follow.

c:\harriet\josep\moem-8.doc