

11/25/98 09:56 FAX 2122190256

SWANKE HAYDEN CONNELL

002

SWANKE HAYDEN CONNELL ARCHITECTS
Field Report

Project Name and Address:	Project No:
OEM	5576A
7 World Trade Center	Project Director/Manager:
New York, NY 10048	Carl Meinhardt / Joseph Aliotta
	Client:
	Silverstein's Properties Inc.
	Contractor:
	Ambassador Construction Co.
Field Report No	Date and Time Present at Site
FR-2	November 24, 1998
Submitted By	Date Prepared
Juan M. Mejia	November 24, 1998
Persons Present at Site:	cc: Martin Schneider / AC, Glenn Pymonto / DCAS
JM / SHCA	Joe Aliotta / SHCA, John Vande Plasse / SHCA

WORK IN PROGRESS:

1. Protective wall @ west side
2. Installation of projector enclosures by Airflex
3. Raised floor @ west side

ADDITIONAL OBSERVATIONS:

1. Conduit above women's core bathroom has to be removed, is below ceiling.
2. Speaker / Strobes have not been relocated @ reception area, Commissioners Suite, Training Room. (As requested in memo).
3. Thermostats have not been relocated as per Power & Telephone Location Plan.
4. Track Light @ press Room feed not in wall, same as feeds for undercabinet lights.
5. Insulation above perforated metal ceiling @ EOC has not been installed.
6. Projection screens have not been installed @ ceilings.
7. Walls @ reception area has to be cut for the installation of the flush wood base. *review for carpet?*
8. LAN room cage for Bell Atlantic equipment has not been installed nor have you submitted shop drawings for review of clearances.
9. Fire Extinguisher cabinet openings @ EOC and corridors are not cut.
10. Please coordinate the location of door # 11A with FSK's revision. (blocking does not seem correct)
11. Door 53A is installed incorrectly, it should be above raised floor not slab.
12. Corner wall at end of corridor in front of door # 52 should be 90 DEG. not as built. Please revise as per plan.

ITEMS TO DOCUMENT / VERIFY

1. Installation of shielding @ floors of Mayor's & Commissioners Conf. Room.

INFORMATION OR ACTION PENDING

1. Alternate solution for routing fuel oil piping @ 1st. Floor FSK' shave been issued for pricing.

ATTACHMENTS

None.

W:\5576\A\QEMDOC\FIELDREPORT\FR11-24-98.DOC

Swanke Hayden Connell Ltd./Swanke Hayden Connell & Partners LLP
 295 Lafayette Street, New York, New York 10012
 212 226 9696, Fax 212 219 0059