

12/03/98 16:15 FAX 2122190256
12/03/98 THU 16:14 FAX 212 615 3700

SWANKE HAYDEN CONNELL
COSENTINI ASSOCIATES LLP

002/002
002

COSENTINI ASSOCIATES LLP ■ TWO PENN. PLAZA, NEW YORK, NY 10121 ■ 212-615-3600 ■ FAX 212-615-3700

JOB MEMORANDUM

TO: Mr. J. Majia - SHCA

SUBJECT: OEM

FROM: B. Lemchev

JOB NO: 1854

CC:

DATE: December 3, 1998

As requested by the Silverstein Properties, the following is a conformation that the day tank rupture basin switch on the detection of the leak will de-energize the transfer pumps and energize the day tank leak light and sound the alarm bell.

X:\WP\FILES\1854.98\VLER1203.M0