

DEC. 3. 1998 4:51PM

SWANKE HAYDEN CONNELL ARCHITECTS

NO. 4170 P. 2/2

SWANKE HAYDEN CONNELL ARCHITECTS**Memorandum**

Project Name and Address:	Project No:
Mayor's Office of Emergency Management	5576A
7 World Trade Center	Project Director/Manager:
New York, New York	Meinhardt/Alotta
	Client:
	Silverstein Properties, Inc.
	Subject:
	Roof shed construction

To	From	Date Prepared
Martin Schneider / Ambassador Construction	Juan M. Mejia	December 3, 1998

As per field visit to the roof today with Mr. Weems of Silverstein's Properties Inc. and Jack Klein of your office the following items were noted.

- 1- Insulated metal panels do not match color control sample.
- 2- Top of metal deck at shed is not at height indicated on SHCA construction documents; therefore creating a very difficult flashing detail with existing building louvers,

The above items should be corrected as soon as possible.

If you need any information or coordination from our office in the above matters please call.

CC: Glen Pymonto / DCAS
Joseph Dominguez / DCAS
John Hughes / OEM
Joe Aliotta / SHCA
John Vande Plasse / SHCA
Josh Ginsburg / SHCA

W:\5576A\OEM\DOCS\MEMO\AMBASSADOR 12-03-98.DOC

Swanke Hayden Connell Ltd./Swanke Hayden Connell & Partners LLP
295 Lafayette Street, New York, New York 10012
212 226 9696, Fax 212 219 0059