NYC 9/11 Public Portal Document

SWANKE HAYDEN CONNELL ARCHITECTS

Fax Message

To: Distribution
(See below)

From: Juan M. Mejia

Fax: (see below)

Job: 5576A

Date: October 8, 1998 Pages: 1

Message:

Please distribute this document to the following people:

OEM	DoITT	Motorola	Cosentini	SM&W
John Hughes	Robert Melaniff	Bob Hudson	Val Lemeshev	William H. Hanley
(212) 442 - 8885	(212) 788 - 2331	(201) 447 - 7800	Bob Slavic	Peter Stern
			(212) 615 - 3700	(212) 725 - 0864

DCAS	OEM
Josep Domingvez	David Litvin
(212) 669 - 3640	
	Sal Lifrieri
	(212) 442 - 8890

Re: Mayor's Office of Emergency Management
7 World Trade Center - 23rd Floor
LAN / Head-End Room Layout

As a follow up from the September 16, 1998 memo re the location of the power below all the cabinets in the LAN/HEAD END room please be advised that the cabinets an or racks have to have a **4" high base minimum in order to fit above the outlets.**

If you have any questions, or need any further clarification, please call me as soon as possible.

Thank You,

Juan M. Mejia
(212) 219 - 6750

\\NEWYORK04\PROJECTS\5576\A\OEMDocs\Fax\LAN-FINAL-10-08-98.doc

Swanke Hayden Connell Ltd./Swanke Hayden Connell & Partners LLP
295 Lafayette Street, New York, New York 10012
212 226 9696, Fax 212 219 0059

NYC-WTC_000167909