


AMBASSADOR CONSTRUCTION CO., INC.



January 25, 1999

Mr. Walter Weems
Silverstein Properties, Inc.
7 World Trade Center
New York, NY 10048



RE. Mayor's Office of Emergency Management
7 World Trade Center - 1, 7 & 23rd Floors
Change Order #059
Amb. Job # S57-5175

Dear Mr. Weems:

We are pleased to submit herewith our change order #059 to perform the following work at the above referenced premises for the sum of TEN THOUSAND NINE HUNDRED FORTY EIGHT DOLLARS (\$10,948.00):

SCOPE OF WORK

In accordance with Cosentini Associates' memo dated 1/22/99, furnish and install (1) duplex separate circuit on rack near column #42 on 1st Floor. The 4" conduit that is being used for the fiber cable will be used. A new drag line will have to be snaked through the existing conduit. The access for the 4" conduit will be on 7th Floor.

Electrical Cost	\$9,445.00
General Conditions	756.00
Overhead & Fee	612.00
Insurance	135.00
Total	\$10,948.00

Please notify this office if we are to proceed with this work.

Very truly yours,

~~AMBASSADOR CONSTRUCTION CO., INC.~~

Martin Schneider
Vice President

MS:ag
cc: Juan Mejia - SHC
Glenn Pymonto - DCAS

Accepted: _____ Dated: _____

c:\wpdocs\oemico59\oemco59 wpd

317 MADISON AVENUE, NEW YORK, NY 10017, 212 922 1020, FAX 212 949 9762