



Silverstein Properties, Inc
 / World Trade Center
 New York, N.Y. 10048
 Telephone: 212-619-6569
 Fax: 212-732-5190

October 23, 1998

Mr. Glenn Pymonto
Department of City Wide Administrative Services
 Division of Real Estate Services
 1 Centre Street, DRES - Room 2000 North
 New York, New York 10007

RE: 7 World Trade Center
 Mayor's Office of Emergency
 Management -1st, 7th, & 23rd Floors
Change Order #20

Dear Mr. Pymonto:

Attached please find change order #20 in the amount of \$12,866.00 submitted by Ambassador Construction for the following scope of work.

In response to RFI#33, provide power for fan power boxes at 277 volts from new circuits. Work includes removing wiring already in place back to the source. The circuitry to be removed is PM-23-M1 #'s 37, 39, 41, and 38 and PP-23-M2 #14, 16 and 46. Wire fans to existing circuits #EHP-23C #'s 4, 3, and 11 and EHP-23B #7 and 4 and a new circuit from panel #EHP-23C #16. All work must be performed through existing finish ceilings.

Electrical	\$8,600.00
Ceiling, Cut and Patch	\$2,500.00
General Conditions	\$888
Overhead and Fee	\$719.00
Insurance	\$159.00
Total	\$12,866.00

If this meets with your approval, please sign and return to my office.

Thank you.

Sincerely,

Walter J. Weems III
 Building Manager

cc: Cathy Gilberti
 Chi Chu
 Bill Dacunto
 Richard Ramos (DCAS)
 Josep Dominguez (DCAS)