

01/22/99 10:51 FAX 2122190256

SWANKE HAYDEN CONNELL

001

SWANKE HAYDEN CONNELL ARCHITECTS**Fax Message**

Attention	Glenn Pymonto	From	Juan M. Mejia				
To	DCAS / DRES	Job Name	OEM				
Address	Municipal Building Suite 2002 South New York, NY 10007	Job No	5576A				
		Phone	212 669-2217	Fax	212 669-3640		
Copy:	Joe Aliotta / SHCA	Date	1/22/99	Time	10:47:31 AM	Page Quantity	1

Re: FSK-56A AND 56D

- AS PER OUR CONVERSATIONS AND PREVIOUS MEMO, PLEASE BE AWARE THAT FSK-56A AND 56D ARE NOT RECOMMENDED BY SHEN MILSON AND THAT A 4" RAISED FLOOR WOULD BE IN CNFLICT WITH SMOKE DETECTORS WHICH WOULD HAVE TO BE CHOPPED IN SLAB.

217