

JUN 21 '00 13:57 FR AMBASSADOR CONSTR. C0212 949 9762 TO 6693640

P.04/04

SWANKE HAYDEN CONNELL ARCHITECTS

Fax Message

Attention	Martin Schneider	From	Juan M. Mejia
To	AMBASSADOR CONSTRUCTION CO. INC.	Job Name	OEM
Address	317 Madison Avenue	Job No	5576A
	New York, New York 10017	Phone	212 922-1020 Fax 212 949-9762
Copy:	Joe Afolia / SHCA	Date	6/2/00 Time 12:01:56 PM Page 3

Re: REPLACEMENT OF FIRE RATED HATCH.

- PLEASE PROVIDE A PROPOSAL TO REMOVE EXISTING FIRE RATED HATCH AT 1ST. FLOOR TANK ROOM, AND TO FURNISH AND INSTALL AN NEW 2'-6" X 2'-6" "FR-2" 2 HOUR RATED HATCH BY BILCO THAT WILL BE CUSTOM FABRICATED TO BE SELF-CLOSING WHEN INERGEN SYSTEM IS ACTIVATED.
- GENERAL CONTRACTOR IS TO VERIFY ALL DIMENSIONS AND USE EXISTING OPENING AND FRAMING.
- PLEASE CONTACT BILCO AT (203) 934-6363 AND ASK FOR A CUSTOM SELF-CLOSING DEVICE TO BE ACTIVATED BY THE FIRE ALARM, OR IN OUR CASE THE INERGEN SYTEM.

Swanke Hayden Connell Ltd/Swanke Hayden Connell LLP
295 Lafayette Street, New York, New York 10012
212 226 9696 Fax 212 219 0059

PAGE 01

JUN 02 2000 12:20