

01 JAN. 25. 2000

11:41PM

212 SWANKE HAYDEN CONNELL ARCHITECTS:ATES LLP

NO. 2046

P. 6/6 002

COSENTINI ASSOCIATES • TWO PENN. PLAZA, NEW YORK, NY 10121 • 212-615-3600 • FAX 212-615-3700

PROJECT MEMORANDUM

TO: Mr. J. Majla - SHCA

SUBJECT: OEM, 7 WTC, 7th FL.
Generator Room

FROM: V. Lemeshev

JOB NO.: 1854

CC: Mr. M. Maybaum
Mr. R. SlavikDATE: January 24, 2000
Revised 1/25/2000

Furnish and install two (2) electric unit heaters, capacity 25 kw each similar to "Trane" model UHEC-25.

Units shall be suitable for operation at 460v, 3ph, 60c and to be provided with unit mounted thermostat.

Each unit shall be connected to the existing electrical panel LP-EHP-7G via 3 #8 AWG wires in ¾" c. Furnish and install 40A, 3P, CB's.

X:\WP\FILES\1854\00\17JMD\24.1\02.DOC