

FEB 15 '00 16:47 FR AMBASSADOR CONSTR. C0212 949 9762 TO 6693640
 04FEB. 15. 2000 4:30PM MAX 21% SWANKE HAYDEN CONNELL ARCHT. CONSULTANTS

P.04/04

GOSENTINI ASSOCIATES • TWO PENN. PLAZA, NEW YORK, NY 10121 • 212-615-3600 • FAX 212-615-3700

PROJECT MEMORANDUM

TO: Mr. J. Majla FROM: Val Lemeshev CC: Mr. M. Maybaum	SUBJECT: OEM 7 WTC 7th Floor Generator Room JOB NO.: 1854 DATE: February 15, 2000
---	---

Installation of electric unit heaters recommended in our memo dated January 24, 2000 is required to warranty emergency start and operation of the generators and to prevent freeze-ups in the generator room and adjacent spaces.

X:\WP\FILES\1854-00\WLC\0215m01.doc

FEB 15 2000 16:36

PAGE.03

** TOTAL PAGE.04 **