

JAN 28 '00 15:41 FR AMBASSADOR CONSTR. C0212 949 9762 TO 6693640
 01 JAN, 20, 2000 1:43 PM X 212 SWANNE HAYLEN CONNELL ASSOCIATES LLP.

P.04/09
 NO. 2047 P. 0/0 0002

COSENTINI ASSOCIATES • TWO PENN. PLAZA, NEW YORK, NY 10121 • 212-615-3600 • FAX 212-615-3700

PROJECT MEMORANDUM

TO:	Mr. J. Majla - SHCA	SUBJECT:	OEM, 7 WTC, 7th FL. Generator Room
FROM:	V. Lemeshev	JOB NO.:	1854
CC:	Mr. M. Maybaum Mr. R. Slavik	DATE:	January 24, 2000 Revised 1/25/2000

Furnish and install two (2) electric unit heaters, capacity 25 kw each similar to "Trane" model UHEC-25.

Units shall be suitable for operation at 460v, 3ph, 60c and to be provided with unit mounted thermostat.

Each unit shall be connected to the existing electrical panel LP-EHP-7G via 3 #8 AWG wires in ¾" c. Furnish and install 40A, 3P, CB's.

X:\WP\PJ\EST\54.0\01\1 JAN 01 12.4.002.DOC