

JUL 02 1999 09:10 FR AMBASSADOR CON.

. TO 6693640

P.02/02

AIR CONDITIONING

KABACK

ENTERPRISES

HEATING

June 30, 1999

Ambassador Construction
317 Madison Avenue
New York, N.Y. 10017

Attn: Mr. Martin Schneider

RE: O.E.M
7 World Trade Center
New York, N.Y.
98-145

Dear Martin:

We have researched the new fuel line route with the building, the architect and Ambassador.

This route is feasible but will require additional work. The following work is required to achieve this installation:

- | | |
|---|---------|
| 1. 28 additional weld on the 8" oil conduit | 15,000- |
| 2. 28 additional welds on the 1 1/4" oil supply | 7,000- |
| 3. 28 additional welds on the 1 1/4" oil return | 7,000- |
| 4. 28 additional welds on the 1 1/4" oil overflow | 7,000- |
| 5. Additional 50 feet of all oil pipe | 5,000- |
| 6. Steel frame hangers every 8 feet | 8,000- |
| 7. Scaffold work differential | 5,000- |

The additional cost for this work is \$54,000.00.

If you have any questions regarding the above, please do not hesitate to contact me.

Very truly yours,

KABACK ENTERPRISES, INC.

Donald M. Murphy
Donald M. Murphy
Vice President

DMM/tms

45 WEST 25TH STREET NEW YORK, N.Y. 10010 (212) 645-5100 FAX: (212) 645-8962

JUL 01 '99 13:50

2126458962

PAGE 01