


12/23/98 17:52 FAX 2122190256

SWANKE HAYDEN CONNELL

002/002
2190059;# 2/ 2

SENT BY:

12-23-98 ; 2:24PM ; CANTOR SEINUK GROUP-



THE CANTOR SEINUK GROUP P.C.

600 MADISON AVENUE • NEW YORK, NEW YORK 10022 • TEL (212) 755-4242 • FAX (212) 752-8924
MEMORANDUM

Date: December 23, 1998

Project: OEM
Seven World Trade Center

To: Juan Mejia
Swanke Hayden Connell Arch.

From: Anca Baron

Subject: First floor - rebars

As per our sketch SKS-FS-7, dated 10-15-98, all the rebars cut, during the chopping of the existing first floor slab, must be restored via a min. 3" overlap weld or a cadweld device. This is necessary for the slab to perform as initially designed.

PROF. YITRAEL A. SEINUK, P.E., F.A.C.I., C.E.N.G., F.I.C.E., Chief Executive Officer • IRWIN G. CANTOR, P.E., F.A.C.I., F.A.S.C.E., President
SILVIAN MARCUS, P.E., Executive Vice President • ESTANISLAD SALCEDO, P.E., Senior Vice President
AHMAD RAHMAN, P.E., Vice President • JEFFREY SMILOW, P.E., Vice President