

JAN 11 '99 15:11 FR AMBASSADOR CONSTR. 00212 949 9762 TO 6694107
12/30/98 WED, 12:11 FAX 212 725 0864

P.05/05

SHEN MILSOM & WILKE

001



Firm: Swanke Hayden Connell Architects

Attn: Juan Mejia

Fax #: (212) 219-0059

Date: Dec 30, 1998

From: Peter J Stern

Pages: 1 (including this page)

Re: Mayor's Office of Emergency Management

SMW Job Number 5149

TECHNOLOGY CONSULTANTS IN
TELECOMMUNICATIONS, AUDIOVISUAL & ACOUSTICS417 Fifth Avenue New York, NY 10016
(212) 725-6800 Fax (212) 725-0864

I have review the catalog cuts of the Lutron lighting system that you sent over. On the sheets that you sent over, Lutron's drawing d1 (sheet 2 of 5) and d2 (sheet 3 of 5) both show the GRX-AV A/V interface. While this is useable, *as long as Ace Audiovisual is informed of the change*, a better choice would be the GRX-RS232 interface. This will provide more flexibility, and what was originally specified.

I have checked with Lutron about the feasibility of changing the audiovisual interfaces from switch closure to RS-232, and they see no reason why it cannot be done. However, there may be other factors that dictated the use of switch closure interfaces. Lutron does not have anything in their files to indicate that this is so, but all possibilities should be considered.

Thank you for your help. If you have any other questions or issues that require discussion, please call me.

Peter J Stern

NEW YORK • WASHINGTON, DC • FLORIDA • CHICAGO • HONG KONG • KUALA LUMPUR

DEC 31 1998 09:00

2122190256

PAGE.02

JAN-11-1999 15:06

212 949 9762

95%

** TOTAL PAGE.05 **

P.05