

NOV 17 '98 16:06 FR AMBASSADOR CONSTR. CO212 949 9762 TO 6694107

P.20/36

NOV 16 1998 08:13 FR R.B.SAMUELS

212 213 4089 TO AMBASSADOR

P.01/01

AMBASSADOR CONSTRUCTION COMPANY, INC.

317 MADISON AVENUE, NEW YORK, N.Y. 10017 TEL (212) 922-1020 FAX: (212) 949-9762

ESTIMATE

DATE 11/12/98

SUB-CONTRACTOR ROBERT B. SAMUELS

PROJECT OEM

TRADE ELECTRIC

LOCATION 7WTC

PHONE NO. 686-6700

SUBS ESTIMATOR GARY FISHBONE

FLOOR 1,7,23,ROOF

ESTIMATED FOR MARTIN SCHNEIDER

ARCHITECT DWG. NO.	LATEST DATE

WORK INCLUDED:

Alteration to work in place per
RFI # 36.

In order to independently feed
ELP-23N and ELP23N-1 we will have
to undo what we have done and alter
our conduits to make a splice prior to
entering panel ELP23N. We will have to
install new wire.

TOTAL PRICE \$ 1275⁰⁰

WORK NOT INCLUDED OR ALTERNATES:

REMARKS: