

OCT 05 1998 07:54 FR R.B.SAMUELS

212 213 4089 TO AMBASSADOR

P.01/01

AMBASSADOR CONSTRUCTION COMPANY, INC.

317 MADISON AVENUE, NEW YORK, N.Y. 10017 TEL (212) 922-1020 FAX: (212) 949-9762

ESTIMATE

DATE 10/13/98

SUB-CONTRACTOR R.B. SAMUELS

PROJECT OEM

TRADE ELECTRIC

LOCATION 7 WTC

PHONE NO. 6866700

SUBS ESTIMATOR GARY FISHBONE

FLOOR 1, 7, 23 + Roof

ESTIMATED FOR Martin Schneider

ARCHITECT DWG. NO.	LATEST DATE

WORK INCLUDED:

Martin - in order to provide the
ammeter and voltmeter, ammeter switch and
voltmeter switch previously non-specified
please ~~not~~ send a purchase order in
the amount of \$6700⁰⁰

The depth of the 2500 Amp switch will
now be INCREASED by 6", from 24" to 30"

Please advise if they want to proceed.
The manufacturer is ON HOLD for this
equipment until we receive notification!

TOTAL PRICE _____

WORK NOT INCLUDED OR ALTERNATES:

REMARKS: