

09 01 03 15 55 FAX 2122100258

SWANKE HAYDEN CONNELL

2001

SWANKE HAYDEN CONNELL ARCHITECTS**Fax Message**

To	From	Juan M. Mejia
Mr. Glenn Pymonto		
DCAS/DRES	Job No.	9902A
	Fax No	(212) 669-3640
	Date	September 1, 1998
	Time	4:00 PM

Message

**RE : Office of Emergency Management
7 World Trade Center**

ATTACHED PLEASE FIND MEMO FROM SHEN MILSON WILKE INC. REGARDING VALUE ENGINEERING COMPARISON BETWEEN C.O. # 4 AND EXHIBIT "A".
PLEASE NOTE THAT ITEM # 2C WILL HAVE TO BE CLARIFIED BY AMBASSADOR AND WE WILL FOLLOW UP IN CLARIFICATION OF ITEM # 3B WITH SHEN MILSON WHEN PETER RETURNS TO HIS OFFICE TOMOROW.

IF YOU NEED ANY OTHER INFORMATION PLEASE CALL.

THANKS.

CC: Martin Schneider / Ambassador Construction (212) 949-9762
Joe Aliotta / SHCA

If there are any problems with this transmission, please call (212) 219-6716

Swanke Hayden Connell Ltd.
Swanke Hayden Connell & Partners L.L.P.
293 Lafayette Street, New York, New York 10012
(212) 226-9696, Fax (212) 219-0059
\\NEWYORK04\PROJECTS\5576\A\Oemdocs\Fax\DCAS-09-01-98 Doc.Doc

Exhibit "A":**AV Equipment Elimination-----****1. RF Distribution system-----**

- Eliminate 13" monitors in the EOC area and the accompanying switching devices. All cabling for the devices will remain.*

2. Press Feeds-----

- The Press AV feed, within the Emergency Operations Room (from the EOC to the press room), should be downgraded from providing service for multiple cameras to providing service for one camera.
- The press AV feed from the press room to street level should be downgraded to a single feed so that the press can have a pooled feed at the street level.

3. External Video Feeds-----

- Eliminate all cabling and switches which were importing external agency camera feeds (e.g. DOT, NYPD, etc.)*

* Architectural impacts should be considered such as covering the 13" monitor furniture cuts with plates. Also the square footage of floor space in the head-end room should be kept for future expansion. Electrical outlets in the head-end room, which were slated for AV equipment, should also be kept.