

09/11/98 13:28 FAX 212 615 3700

COSENTINI ASSOCIATES

001/005

Cosentini

ASSOCIATES LLP

C O N S U L T I N G E N G I N E E R S

TWO PENNSYLVANIA PLAZA + NEW YORK NY 10121

(212) 615-3600

FAX: (212) 615-3700

FAX COVER SHEET

Date: 9/11/98

From: SWAM GOUNDER

To: JOE ALIOTTA

Company: SHCA

Fax No: 669-4107

Re: OEM

Total No. of Pages: 5

Job. No: 1854

Comments:

1. PANEL DOES NOT CALL FOR SHORT CIRCUIT RATINGS. SPECIFICATION CALLS FOR SHORT CIRCUIT RATING. (SPECIFICATION PAGE 16400-6
2. BY CODE REFERENCE SPEC AT PANEL IS #2. THERE IS NO UPGRADE.

Original will be sent via:

☐ Mail

☐ Fed Ex

☐ Messenger

☐ Original will not be sent

cc: Name:

Company


Fax No.

09/11/98 13:29 FAX 212 615 3700

COSENTINI ASSOCIATES

004/005

3



Owner
 Silverstein Properties, Inc.
 521 Fifth Avenue NY, NY 1017
 Architects
 Swako Hayden Connell
 205 Lafayette St. NY, NY 1001
 Mechanical Engineer
 Cosentini Associates LLP
 Two Pennsylvania Plaza NY, NY 1001
 Structural Engineer
 The Cantor Seinuk Group, P.C.
 600 Madison Avenue NY, NY 1001
 Construction Manager
 Ambassador Construction Co., Inc.
 317 Madison Avenue NY, NY 1001

rev no	date	description
1/28/98	DD	ISSUANCE
4/6/98		ISSUED FOR REVIEW - 100% CD
5/13/98		ISSUED FOR P.A. REVIEW
1	5/15/98	ADDENDUM #1

DRAWING
 NO. E4.03