

MAR. 21. 2000 12:52PM

SWANKE HAYDEN CONNELL ARCHITECTS

NO. 3497 P. 2/3

**SWANKE HAYDEN CONNELL ARCHITECTS****Memorandum**

---

**TO:** Glenn Pymonto  
**DCAS/DRES**

**FROM:** Juan M. Mejia

**SUBJECT:** Mayor's Office of Emergency Management  
7 World Trade Center  
SHCA Project No. 5576A  
*"P.A. Inspectors request for Fuel Tank Room."*

**DATE:** March 21, 2000

---

Dear Glenn:

As a result of a preliminary walk-through for the final inspection of the fuel oil tank room, the Port Authority has requested that the access hatch to the tank room be self-closing and be tied in to the Inergen discharge system.

We have contacted Ambassador Construction and are in the process of producing a wiring diagram and pricing for this work.

CC: Mr. Joe Aliotta / SHCA

**Swanke Hayden Connell Ltd.**  
**Swanke Hayden Connell & Partners LLP**  
295 Lafayette Street, New York, New York 10012  
(212) 228-8685, Fax (212) 219-0059

W:\5576A\Oemdocs\Memo\DCAS Memo-FR.Hatch3-21-00.Doc