

01/22/99 15:08 FAX 2122190256

SWANKE HAYDEN CONNELL

002

01/22/99 FRI 09:37 FAX 212 725 0864

SHEN WILSON & WILKE

001

Firm: Swanke Hayden Connell Architects

Attn: Juan Mejia

Fax #: (212) 219-0059

Date: Jan 22, 1999

From: Peter J Stern

Pages: 1 (including this page)


Re: Mayor's Office of Emergency Management

SMW Job Number 5149

This fax is in response to the three (3) issues you brought upon your telephone message this morning.

1. Fiber - There is no problem running fiber optic cable in the same conduit as electric (120VAC) power, provided that there are no metallic strength members, or any other metal components, in the fiber optic cable.
2. Mayor's Office - The maximum mounting height of the plasma panels is 5'-6" AFF.
3. Press Room - The option that makes the most sense is Option B, as shown on your sketches "SK-56B" and "SK-56E."

If you have any other questions or issues that require discussion, please call me.



Peter J Stern