



ROBERT B. SAMUELS INC.

Electrical Contractors

June 8, 1998

To: Martin Schneider

From: Alan S. Fishbone

Re: O.E.M

Addendum #1

- | | | |
|-----|--|--------------------------|
| 1. | Change service switch from 2000 A to 2500 Amp 3 phase 4 wire. Provide shunt trip to various circuit breaker as per the panel schedule. | \$ 11,859.00 |
| 2. | To upgrade size of the feeders as per the revised riser lay out. | \$ 15,030.00 |
| 3. | Light fixture type D-1 (dimming ballast) to be provided with EM ballast. | \$ 4,917.00 |
| 4. | To provide 3 additional GFI outlets, g #2/0 to building steel, add 30 A 3 pha and tap ahead of transformer | k with switch 00 |
| 5. | Additional pre-action system devices (| 00 ← ? |
| 6. | Additional fire alarm system devices. | 00 ✓ |
| 7. | Additional work on A.V. system | .00 |
| 8. | Additional 13 transducers with accessories. | \$ 12,988.00 |
| 9. | Additional raised floor grounding | \$ 45,100.00 — Too High. |
| 10. | Additional security system devices. | \$ 7,493.00 |
| | | <u>\$120,900.00</u> |
- DAMPERS were existing in original Contract. \$39,446!*

ADDITIONAL WORK AFTER ADDENDUM #1

To provide power to 38 Dampers and control wiring (Dampers by others). ?
\$ 39,446.00

To furnish and install leak detection system consisting of 21 leak detector sensors and control panel. ✓
\$ 58,500.00