

DEC. 9, 1998 9:39AM

SWANKE HAYDEN CONNELL ARCHITECTS

NO. 4467 P. 2/2

SWANKE HAYDEN CONNELL ARCHITECTS**Memorandum****Project Name and Address:**

Mayor's Office of Emergency Management
7 World Trade Center
New York, New York

Project No:

5576A

Project Direct or Manager:

Meinhardt/Allotta

Client:

Silverstein Properties, Inc.

Subject:

P.A. Approval

To

John Hughes / OEM.

FromJuan M. Mejia **Date Prepared**

December 9, 1998

As per my conversation with you, Sal Lifrieri and Mike Pisano of Vikonics; I informed that our final request for approval of the release of doors #'s 40A & 40B has been rejected by the P.A.. In an informal review the Port rejected our final solution for the release of this doors, and therefore we will not have a Certificate of Occupancy by your move in date, unless we submit an acceptable solution by no later than this Friday.

In my conversation with Vikonics, Mike proposed to tie in the two doors to a door release button at the receptionist desk. He was going to try to find a button that had a MEA approval for NYC as requested by the P.A.

We can not be sure that the P.A. will approve this and if we don't receive this information by today we can not set up the review appointment for Friday.

If you need any more information regarding this matter please call.

CC: Glen Pymeto / DCAS
Joseph Dominguez / DCAS
Sal Lifrieri / OEM
Chi k. Chu / SP
Walter Weems III / SP
Mike Pisano / VI
Martin Schneider / AC
Joe Aliotta / SHCA
John Vande Plasse / SHCA
Josh Ginsburg / SHCA

NEWYORK\PROJECTS\576A\OEM\DCAS\WEM\OEM 12-9-98.DOC

Swanke Hayden Connell Ltd./Swanke Hayden Connell & Partners LLP
295 Lafayette Street, New York, New York 10012
212 226 9696, Fax 212 219 0059