

OEM
 7 World Trade Center
 Project No.5576A
 Revised 09/16/98

Swanke Hayden Connell Architects

Total RFI's Received 37
 Total Responses Received 37

RFI LOG



31	9/28/98	WHAT IS THE FINISH OF THE DR TYPE RINGS ON THE FIXTURE TYPE "F"	DR RINGS SHOULD BE BRUSHED ALUMINUM FINISH.	9/28/98		

01/01/1995 00:08

2129499762

AMBASSADOR CONSTR

PAGE 07