

8/98 THU 07:44 FAX 212 615 3700
14/98 15:40 FAX 2122190256
OCT 14 '98 11:04 FR AMBASSADOR CONSTR. CO212 949 9762 TO 2190059

COSENTINI ASSOCIATES LLP
SWANKE HAYDEN CONNELL
CO212 949 9762 TO 2190059

001
002/002
P.01/01

AMBASSADOR CONSTRUCTION CO., INC.



MR. J. MAJIA . 1p.
219-0059

REQUEST FOR INFORMATION

To: Juan Mejia
Swanke Hayden Connell

RE: Mayor's Office of Emergency Management
7 World Trade Center
1, 7 & 23rd Floors
Amb. Job # S57-5175

Date: October 14, 1998

RFI #34. Silverstein feels that they need more protection to the fuel oil piping in the generator room in case of leaks. There is none provided.

Please advise.

MS:am
C:\WPWIN6\WPD\DCS\DEM\OEM41.WPD

Dwg's have been reviewed by Silverstein and PA.
Documents call for two (2) high level twitches in series and solenoid valve on supply line.
Please, advice if more protection required.
J. Lemethu C.A. 10.15.98

317 MADISON AVENUE, NEW YORK, NY 10017, 212 922 1020, FAX 212 949 9762

** TOTAL PAGE.01 **