

01254
 7 World Trade Center
 Project No.5576A
 Revised 07/22/98

Swanick Haydon Connell Architects
 Total RFI's Received 12
 Total Responses Received 10

RFI LOG

RFI NO.	DATE RECD	SUBJECT/QUESTIONING NO.	RESPONSE	DATE RESP.	#BUS DAYS	Remarks
10	7/31/98	R.B. SAMUELS NEEDS SIZING OF PIPING AND JUNCTION BOXES FOR NOVALINK DATA/TEL/VOICE/RADIO OUTLETS. THEY HAVE INCLUDED 3/4" EMT AND SINGLE "J" BOX.				
11	7/31/98	CLARIFY FIXTURE TYPE IN ROOM # 2304 IS IT "E" OR "D-1" ?	IT IS TYPE "E" AS NOTED ON DRAWINGS.	8/4/98	4	
12	8/3/98	MISCELLANEOUS ELECTRICAL AND HVAC QUESTIONS (SEE ATTACHED LIST)			(36,010)	
13						
14						
15						
16						
17						

** 50.30% TOTAL **

01/01/1995 03:49 2129499762

AMBASSADOR CONSTR

PAGE 03