

02/02/99 16:29 FAX 212 615 3700

COSENTINI ASSOC. LLP

002/002

COSENTINI ASSOCIATES LLP ■ TWO PENN. PLAZA, NEW YORK, NY 10121 ■ 212-615-3600 ■ FAX 212-615-3700

JOB MEMORANDUM**TO:** Mr. Glenn Mento**SUBJECT:** Mayor's Office of
Emergency Management
7 World Trade Center**FROM:** Sivam Gounder**CC:** Mr. Joseph Aliotta -SHCA
File**JOB NO:** 1854**DATE:** February 2, 1999

A. LOAD BACKED UP BY EMERGENCY GENERATORS

1. Entire 23rd floor electrical load
2. Radio room on the roof.
3. 1st and 7th floor electrical load associated with Mayor's Office of Emergency Management.
4. Freight elevator.

B. LOAD BACKED UP BY UPS AND EMERGENCY GENERATORS

1. Motorola equipment on roof.
2. Motorola equipment on 23 rd floor in room 23-50.
3. Selected outlets in Watch Command.
4. Selected equipment (PCs and Monitors) in Emergency Operation Center.

Mayor Conf & Office → UPS City