

01/05/99 16:37 FAX 2122190256

SWANKE HAYDEN CONNELL

002

SWANKE HAYDEN CONNELL ARCHITECTS**Memorandum**

TO: Glenn Pymonto
DCAS/DRES

FROM: Juan M. Mejia

SUBJECT: Mayor's Office of Emergency Management
7 World Trade Center
SHCA Project No. 5576A
"Project Progress Summary"

DATE: January 5, 1999

As per your request this memo is issued to inform you that Silverstein's request of cladding the frames around the 7th Floor generator louvers with stainless steel will have no effect on the operation of the generators, and that this request is only a matter of esthetic preference.

SHCA has issued Silverstein's Properties renderings of the north façade showing both stainless steel and aluminum trim, with our recommendations for using the aluminum trim to match the building.

CC: Mr. Walter Weems III / SP
Mr. Joe Aliotta / SHCA

Swanke Hayden Connell Ltd.
Swanke Hayden Connell & Partners LLP
295 Lafayette Street, New York, New York 10012
(212) 228-9696, Fax (212) 219-0059

\\NEWYORK04\PROJECTS\5576\A\Oemdocs\Memo\DCAS 1-5-99- Dot