

PRECISION TESTING & BALANCING, INC.

**1785 NEREID AVENUE, BRONX, N.Y. 10466
(718) 994-2300 FAX (718) 994-2341**

REPORT

ON

TESTING & BALANCING

THE

SUPPLY AIR SYSTEMS

AT

**MAYOR'S OFFICE OF EMERGENCY MANAGEMENT
7 WORLD TRADE CENTER
NEW YORK, NEW YORK**

PREPARED FOR

**KABACK ENTERPRISE INC.
41 WEST 25TH STREET
NEW YORK, NEW YORK 10010**

PTB JOB # 3426

MARCH 2, 1999

**PRECISION TESTING
& BALANCING INC.**

Page 1 of 1

VENTILATION TEST REPORT

TEST BY _____

DATE March 2, 1999

JOB NAME MAYOR'S OFFICE OF EMERGENCY MANAGEMENT

ADDRESS 7 WORLD TRADE CENTER NEW YORK, NEW YORK

PREPARED FOR KABACK ENTERPRISES, INC.

SYSTEM AC - 2 EQUIP. LOCATION 23rd FLR. LAN ROOM

FAN: MAKE	<u>LIEBERT</u>
SIZE	<u>BU071WGAAM</u>

MOTOR: HP	<u>2</u>	RPM	<u>1750</u>
VOLTAGE: RATED	<u>460</u>	ACTUAL	<u>480</u>
AMPERAGE: RATED	<u>3.1</u>	ACTUAL	<u>3.1</u>

STATIC PRESSURE:	
SUCTION	<u> </u> IN. W.G.
DISCHARGE	<u> </u> IN. W.G.

FAN RPM: REQD	<u> </u>	ACTUAL	<u> </u>
SYSTEM CFM: REQD	<u> </u>	ACTUAL	<u> </u>

Remarks:

SYSTEM BALANCED ON A BOX BY BOX BASIS Y/N ()

DWG	AREA SERVED	OPENING			K FACTO	REQUIRED				FINAL		REMARKS
		NO	SIZE	TYPE		VEL	CFM			VEL	CFM	

**PRECISION TESTING
& BALANCING INC.**

Page 1 of 1

VENTILATION TEST REPORT

TEST BY _____

DATE March 2, 1999JOB NAME MAYOR'S OFFICE OF EMERGENCY MANAGEMENTADDRESS 7 WORLD TRADE CENTER NEW YORK, NEW YORKPREPARED FOR KABACK ENTERPRISES, INC.SYSTEM AC 3 EQUIP. LOCATION 23rd FLR. LAN ROOM
M1-23

FAN: MAKE	<u>LIEBERT</u>
SIZE	<u>BU071WGAAM</u>

MOTOR: HP	<u>2</u>	RPM	<u>1750</u>
VOLTAGE: RATED	<u>460</u>	ACTUAL	<u>480</u>
AMPERAGE: RATED	<u>3.1</u>	ACTUAL	<u>3.0</u>

STATIC PRESSURE:

SUCTION	<u> </u>	IN. W.G.
DISCHARGE	<u> </u>	IN. W.G.

FAN RPM: REQD	<u> </u>	ACTUAL	<u> </u>
SYSTEM CFM: REQD	<u> </u>	ACTUAL	<u> </u>

Remarks:

SYSTEM BALANCED ON A BOX BY BOX BASIS Y/N ()

DWG	AREA SERVED	OPENING			K FACTO	REQUIRED				FINAL		REMARKS
		NO	SIZE	TYPE		VEL	CFM			VEL	CFM	

