

05/20/2002 14:49 FAX 7188974537

SAMSON MANAGEMENT CORP

0025
010

05/15/2002 20:51 FAX 8457821872

05/15/2002 22:01 2126799392

SCILAB NYC

PAGE 10/19

**SCIENTIFIC LABORATORIES, INC.**117 EAST 30TH STREET
NEW YORK, NY 10016

TEL: (212) 679-8600 - FAX: (212) 679-9392

PLM Bulk Asbestos Report**AA Asbestos Services****Attn: Jean Rensink****36 Eagle Street****Walton Lake Park****Monroe, NY 10950****Date Received** 05/15/2002 **SciLab Job No.** 202052555**Date Examined** 05/15/2002 **P.O. #** Rensink**ELAP Number** 11480 **Page** 1 of 3**RE:** 120 Liberty St. AKA 125 Cedar St. NY, NY/Penthouse

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
1	202052555-01		NA

Location: West Wall Lip Of Cabinet**Description:** Bulk Material**Asbestos Types:****Other Material:****Comment:** INSUFFICIENT SAMPLE SIZE

2	202052555-02	Yes	<1.0% ¹
---	--------------	-----	--------------------

Location: West Window Sill**Description:** Grey, Heterogeneous, Bulk Material**Asbestos Types:** Chrysotile 0.25 %**Other Material:** Cellulose 8 %, Fibrous glass 2 %, Non-fibrous 89.75 %

3	202052555-03	Yes	<1.0% ¹
---	--------------	-----	--------------------

Location: Kitchen Sink**Description:** Grey, Heterogeneous, Bulk Material**Asbestos Types:** Chrysotile Trace**Other Material:** Cellulose 12 %, Fibrous glass 40 %, Synthetic fibers Trace,
Non-fibrous 48 %

4	202052555-04	Yes	<1.0% ¹
---	--------------	-----	--------------------

Location: Floor In Front Of Kitchen Sink**Description:** Grey, Heterogeneous, Bulk Material**Asbestos Types:** Chrysotile Trace**Other Material:** Cellulose 25 %, Fibrous glass 35 %, Synthetic fibers Trace,
Non-fibrous 40 %

05/20/2002 14:50 FAX 7188974537

SAMSON MANAGEMENT CORP

WJ 040
011

05/15/2002 20:51 FAX 8457821872

05/15/2002 23:01 2126799392

SCILAB NYC

PAGE 11/19

**SCIENTIFIC LABORATORIES, INC.**

117 EAST 30TH STREET

NEW YORK, NY 10016

TEL: (212) 678-8600 • FAX: (212) 678-8392

PLM Bulk Asbestos Report**AA Asbestos Services****Attn: Jean Rensink****36 Eagle Street****Walton Lake Park****Monroe, NY 10950****Date Received** 05/15/2002 **SciLab Job No.** 202052555**Date Examined** 05/15/2002 **P.O. #** Rensink**ELAP Number** 11480 **Page** 2 of 3**RE:** 120 Liberty St. AKA 125 Cedar St. NY, NY/Penthouse

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
5	202052555-05	No	NAD ¹

Location: Bathroom Floor**Description:** Grey, Heterogeneous, Bulk Material**Asbestos Types:****Other Material:** Cellulose 8. %, Fibrous glass 25. %, Non-fibrous 67. %

6	202052555-06	No	NAD ¹
---	--------------	----	------------------

Location: Closet Bedroom Atop Of Dresser**Description:** Grey, Heterogeneous, Bulk Material**Asbestos Types:****Other Material:** Animal hair Trace, Cellulose 40. %, Fibrous glass 40. %, Synthetic fibers 8. %, Non-fibrous 12. %

7	202052555-07	Yes	<1. % ¹
---	--------------	-----	--------------------

Location: Main Floor**Description:** Grey, Heterogeneous, Bulk Material**Asbestos Types:** Chrysotile Trace**Other Material:** Animal hair 1. %, Cellulose 25. %, Fibrous glass 25. %, Synthetic fibers Trace, Non-fibrous 49. %

8	202052555-08	No	NAD ¹
---	--------------	----	------------------

Location: Hallway Floor**Description:** Grey, Heterogeneous, Bulk Material**Asbestos Types:****Other Material:** Cellulose 10. %, Fibrous glass 2. %, Non-fibrous 88. %

05/20/2002 14:50 FAX 7188974537
05/15/2002 20:51 FAX 8457821872

SAMSON MANAGEMENT CORP

0027
0012

05/15/2002 23:01 2126799392

SCILAB NYC

PAGE 12/13

**SCILAB****SCIENTIFIC LABORATORIES, INC.**

117 EAST 30TH STREET

NEW YORK, NY 10016

TEL: (212) 679-8500 • FAX: (212) 679-9392

PLM Bulk Asbestos ReportAA Asbestos Services
Attn: Jean Rensink
36 Eagle Street
Walton Lake Park
Monroe, NY 10950Date Received 05/15/2002 SciLab Job No. 202052555
Date Examined 05/15/2002 P.O. # Rensink
ELAP Number 11480 Page 3 of 3
RE: 120 Liberty St. AKA 125 Cedar St. NY, NY/Penthouse

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
9	202052555-09	No	NAD ¹

Location: QC Top Of Stairway Leading To Roof

Description: Gray, Heterogeneous, Cementitious, Bulk Material

Asbestos Types:

Other Material: Cellulose 2. %, Fibrous glass Trace, Non-fibrous 98. %

Reporting Notes:

(1) Composite analysis results for heterogeneous debris samples may be highly variable due to inhomogenities in materials present:

Analyzed by: David Roderick

*NAD/NSD = no asbestos detected; NA = not analyzed; NA/PS = not analyzed / positive stop; PLM Bulk Asbestos Analysis by EPA 600/M4-82-020 per 40 CFR 763 (NVLAP Lab #200546-0) and ELAP PLM Analysis Protocol 198.1 for New York samples (NYSDOH ELAP Lab # 11480); Note: PLM is not consistently reliable in detecting asbestos in floor coverings and similar non-friable organically bound materials. TEM is currently the only method that can be used to determine if this material can be considered or treated as non-asbestos-containing in New York State (also see EPA Advisory for floor tile, FR 59, 146, 38970, 8/1/94). National Institute of Standards and Technology Accreditation requirements mandate that this report must not be reproduced except in full without the approval of the laboratory. This PLM report relates ONLY to the items tested. AIHA# 102843; VT Cert# ALD16055

Reviewed By: _____