

SciLab Job #: 202023224

Client Name: TRC Environmental Corporation

Phase Contrast Microscopy (PCM) Fiber Results

35052-0000-00007; New York City Law Department; 100 Church Street, AMBIENT

SciLab Sample #	Client Sample # / Location	Date Collected	Flow Rate (liters/min.)	Duration (min.)	Air Filtered (liters)	Fields	Fibers	Fiber Density (Fibers/mm ²)	Fibers Conc. (Fibers/cc)	TWA
01	GS-21202-ASB-0677 6th Floor-Northeast Side Of Hallway	2/21/02	5	360	1800	100	2	2.55	< 0.001	
02	GS-21202-ASB-0678 6th Floor-Northwest Side Of Hallway	2/21/02	5	360	1800	100	1	1.27	< 0.001	
03	GS-21202-ASB-0679 Room 6-310A	2/21/02	5	180	900	100	1	1.27	< 0.003	
04	GS-21202-ASB-0680 Room 6-316	2/21/02	5	180	900	100	2	2.55	< 0.003	
05	GS-21202-ASB-0681 Blank	2/21/02	0	0	0	100	0.5	0.64		Footnotes: 1
06	GS-21202-ASB-0682 Blank	2/21/02	0	0	0	100	0.5	0.64		Footnotes: 1

Reporting Notes:

(1) Fibers/cc cannot be calculated for samples (or blanks) with no air volume.

Analyzed by: Marvin Brothers *MB Brothers*; Date Analyzed: 2/22/02

Samples analyzed by NIOSH 7400(A) Method, Issue #2, 8/15/94: Limit of Detection= 5.5 fibers per 100 fields or 7 fibers/mm²: This report relates ONLY to the sample analysis expressed as fibers/sq mm of filter area: ND=No fibers observed: NA= Not Analyzed; Walton-Beckett graticle field area = 0.00785 mm²: TWA = 8 Hr TWA calculation assumes zero exposure for remainder of 8 hr period not sampled: Upper 95% Confidence limit (Employers Compliance Test)- Calculated as a one sided UCL to determine 95% certainty of compliance with the 0.01 fiber/cc standard: Estimated relative standard deviation: Intralab Sr=0.405, Interlab Sr=0.45, New York samples (NYSDOH ELAP Lab # 11480): National Institute of Standards and Technology Accreditation requirements mandate that this report must not be reproduced except in full without the approval of the laboratory. AIHA # 102843.