NYC 9/11 Public Portal Document

TRC
Customer-Focused Solutions

July 15, 2002

Mr. G. Foster Mills
Managing Attorney
New York City Law Department
100 Church Street
New York, New York 10007

Re: Report of Ongoing Air Monitoring Performed On June 18, 2002
TRC Project Number: 35052-0000-00011

Dear Mr. Mills:

TRC Engineers, Inc. (TRC) performed air monitoring on June 18, 2002 in the space occupied by New York City Law Department and exterior to 100 Church Street as part of the ongoing air-monitoring program.

Representative samples for Total Dust, Metals, Asbestos, Carbon Dioxide, Carbon Monoxide, Temperature and Relative Humidity were collected outside and inside the building on the 2nd and 3rd floors.

Most results were below the analytical detection limit and all were below (i.e., better than) the respective Occupational Safety and Health Administration (OSHA) Permissible Exposure Limit (PEL). A copy of the test results along with OSHA permissible exposure limits for detected parameters is attached.

The results of this on-going sampling effort support and confirm TRC's recommendation in the April 8, 2002 Environmental Health Risk Assessment Report to reoccupy the space.

Should you have any questions or comments, please feel free to contact us at (212) 563-3933.

Sincerely,

TRC ENGINEERS, INC.

Nitin Dave

Nitin Dave, CIH, CSP, PE
Senior Project Manager

Enclosure
Cc: Mal Higgins - NYCLD
Susan Kath - NYCLD

134 West 29th Street, 11th Floor • New York, New York 10001
Telephone 212-563-3933 • Fax 212-349-4648

NYC-WTC_000174454