

EMSL Analytical, Inc.

307 West 38th Street, New York, NY 10018

Phone: (212) 290-0051 Fax: (212) 290-0058 Email: manhattanlab@emsl.com

EMSLAttn: TRC Environmental Consultants
1430 Broadway
10th Floor
New York, NY 10018

Fax: (212) 221-7840

Phone: 212-221-7822

Project: 35052-0000-00017 / New York City Law Department / 100
Church St.

Customer ID: TRCE51

Customer PO:


Received: 03/15/03 10:53 AM

EMSL Order: 030304175

EMSL Project ID:

Lead in Wipes by Flame AAS (SW 846, 7420)

Client Sample Description	Lab ID	Analyzed	Area Sampled	Lead Concentration
ZD031503LW2001 Inside HVAC Duct - Suplay Air/12x12/20th Fl. W.Side	0001	3/15/03	144 in ²	<10.0 µg/ft ²
ZD031503LW2002 Inside HVAC Duct- Suplay Air/12x12/20th Fl NW Side	0002	3/15/03	144 in ²	<10.0 µg/ft ²
ZD031503LW2003 Inside HVAC Duct- Suplay Air/12x12/20th Fl Cnt.of N	0003	3/15/03	144 in ²	<10.0 µg/ft ²

Laboratory Manager
or other approved signatoryReporting limit is 10 µg/wipe. The QC data associated with the sample results included in this report meet the recovery and precision requirements established by the AHA, unless
specifically indicated otherwise in the comment section.

ACCREDITATIONS: AHA Environmental Lead Laboratory Approval Program #102581