NYC 9/11 Public Portal Document



EMSL Analytical, Inc.
307 West 38th Street, New York, NY 10018
Phone: (212) 290-0051 Fax: (212) 290-0058 Email: manhattanlab@emsl.com

Attn: TRC Environmental Consultants
1430 Broadway
10th Floor
New York, NY 10018
Fax: (212) 221-7840 Phone: 212-221-7822
Project: 35052-0000-00017/ NEW YORK CITY LAW DEPARTMEMT/ 100 CHURCH ST./ AMBIENT

Customer ID: TRCE51
Customer PO:
Received: 03/22/03 11:06 PM
EMSL Order: 030304708
EMSL Project ID:
Analysis Date: 3/23/2003

## Phase Contrast Microscopy (PCM) Fiber Count by NIOSH 7400, Fourth Edition, Issue 2, 8/15/94

| Sample | Location | Sample Date | Volume | Fibers | Fields | LOD (fib/cc) | Fibers/ mm² | Fibers/ cc | Notes |
|---|---|---|---|---|---|---|---|---|---|
| ZD032203ASBAI R2001<br>*030304708-0001* | 20TH FLOOR-N/W SIDE | 3/22/2003 | 1533.33 | <5.5 | 100 | 0.002 | <7.0 | <0.002 | |
| ZD032203ASBAI R2002<br>*030304708-0002* | 20TH FLOOR-N/E SIDE | 3/22/2003 | 1539.64 | <5.5 | 100 | 0.002 | <7.0 | <0.002 | |
| ZD032203ASBAI R2003<br>*030304708-0003* | 20TH FLOOR-N/W SIDE | 3/22/2003 | 1533.33 | <5.5 | 100 | 0.002 | <7.0 | <0.002 | |
| ZD032203ASBAI R2004<br>*030304708-0004* | 20TH FLOOR-N/E SIDE | 3/22/2003 | 1539.64 | <5.5 | 100 | 0.002 | <7.0 | <0.002 | |
| ZD032203ASBAI R2005<br>*030304708-0005* | 20TH FLOOR-N/W SIDE | 3/22/2003 | 1918.24 | <5.5 | 100 | 0.001 | <7.0 | <0.001 | |
| ZD032203ASBAI R2006<br>*030304708-0006* | 20TH FLOOR-N/E SIDE | 3/22/2003 | 1918.24 | <5.5 | 100 | 0.001 | <7.0 | <0.001 | |
| ZD032203ASBAI RFB01<br>*030304708-0007* | BLANK | 3/22/2003 | 0.00 | <5.5 | 100 | | <7.0 | | Field Blank |

Rey Cross
Analyst

José Quiroga
Laboratory Manager
or other approved signatory

Limit of detection is 7 fibers/mm². The laboratory is not responsible for data reported in fibers/cc, which is dependent on volume collected by non-laboratory personnel. This report relates only to the samples reported above. This report may not be reproduced, except in full, without written approval by EMSL.
Analysis performed by EMSL Manhattan (NY State ELAP #11150G, AIHA #102581)



CITY_21MC100_012557938

NYC-WTC_000174553