

EMSL Analytical, Inc.

307 West 38th Street, New York, NY 10018

Phone: (212) 290-0051 Fax: (212) 290-0058 Email: manhattanlab@emsl.com



Attn: TRC Environmental Consultants
1430 Broadway
10th Floor
New York, NY 10018

Fax: (212) 221-7840 Phone: 212-221-7822

Project: 35052-0000-00017/ NEW YORK CITY LAW
DEPARTMENT/ 100 CHURCH ST./ AMBIENT

Customer ID: TRCE51

Customer PO:

Received: 03/06/03 3:56 PM

EMSL Order: 030303598

EMSL Project ID:

Analysis Date: 3/6/2003

**Phase Contrast Microscopy (PCM) Fiber Count by NIOSH 7400, Fourth Edition, Issue 2,
8/15/94**

Sample	Location	Sample Date	Volume	Fibers	Fields	LOD (fib/cc)	Fibers/ mm ³	Fibers/ cc	Notes
NA030603ASBAI R2001 030303598-0001	20TH FLOOR-EAST CORIDOR ENTRANCE	3/6/2003	1520.70	<5.5	100	0.002	<7.0	<0.002	
NA030603ASBAI R2002 030303598-0002	20TH FLOOR-WEST CORIDOR ENTRANCE	3/6/2003	1527.02	<5.5	100	0.002	<7.0	<0.002	
NA030603ASBAI R2003 030303598-0003	20TH FLOOR-EAST CORIDOR ENTRANCE	3/6/2003	1520.70	<5.5	100	0.002	<7.0	<0.002	
NA030603ASBAI R2004 030303598-0004	20TH FLOOR-WEST CORIDOR ENTRANCE	3/6/2003	1527.00	<5.5	100	0.002	<7.0	<0.002	
NA030603ASBAI R2005 030303598-0005	BLANK	3/6/2003	0.00	<5.5	100		<7.0		Field Blank

Jeremy Robertson

Analyst

Laboratory Manager
or other approved signatory

Limit of detection is 7 fibers/mm³. The laboratory is not responsible for data reported in fibers/cc, which is dependent on volume collected by non-laboratory personnel. This report relates only to the samples reported above. This report may not be reproduced, except in full, without written approval by EMSL.
Analysis performed by EMSL Manhattan (NY State ELAP #11506, AIHA #102591)

PCM2

1