

EMSL Analytical, Inc.

307 West 36th Street, New York, NY 10018

Phone: (212) 290-0051 Fax: (212) 290-0058 Email: manhattanlab@emsl.com

EMSL

Attn: TRC Environmental Consultants
1430 Broadway
10th Floor
New York, NY 10018

Customer ID: TRCE51
Customer PO:
Received: 02/12/03 4:32 PM

Fax: (212) 221-7840 Phone: 212-221-7622


EMSL Order: 030302198

Project: 35052-0000-00017 / 100 Church St.

EMSL Project ID:

Lead In Wipes by Flame AAS (SW 846, 7420)

Client Sample Description	Lab ID	Analyzed	Area Sampled	Lead Concentration
ZD021203LW2001 Outside of box / 12 x12 / 20th floor	0001	2/12/03	144 in ²	<10.0 µg/ft ²
ZD021203LW2002 Outside of box / 12 x12 / 20th floor	0002	2/12/03	144 in ²	<10.0 µg/ft ²
ZD021203LW2003 Field Blank	0003	2/12/03	n/a	<10.0 µg/wipe



Laboratory Manager
or other approved signatory

Reporting limit is 10 µg/wipe. The QC data associated with the sample results included in this report meet the recovery and precision requirements established by the AIHA, unless specifically indicated otherwise in the comment section.

ACCREDITATIONS: AIHA Environmental Lead Laboratory Approval Program #102581