

EMSL Analytical, Inc.

307 West 38th Street, New York, NY 10018

Phone: (212) 290-0051 Fax: (212) 290-0058 Email: manhattanlab@emsl.com



Attn: TRC Environmental Consultants
1430 Broadway
10th Floor
New York, NY 10018
Fax: (212) 221-7840 Phone: 212-221-7822
Project: 35052-0000-00017 / New York City Law Department / 100 Church St.

Customer ID: TRCE51
Customer PO:
Received: 03/03/03 6:37 PM
EMSL Order: 030303327
EMSL Project ID:

Lead in Wipes by Flame AAS (SW 846, 7420)

Client Sample Description	Lab ID	Analyzed	Area Sampled	Lead Concentration
ZD030303LW2001 Inside Return air Duct / Center of W E Section	0001	3/3/03	144 in ²	<10.0 µg/ft ²
ZD030303LW2002 Inside Supply Air Duct / Center of E Section	0002	3/3/03	144 in ²	<10.0 µg/ft ²
ZD030303LW2003 Field Blank	0003	3/3/03	n/a	<10.0 µg/wipe
ZD030303LW2004 Inside Supply Air Duct / Center of N E Section	0004	3/3/03	144 in ²	<10.0 µg/ft ²

Laboratory Manager
or other approved signatory

Reporting limit is 10 µg/wipe. The QC data associated with the sample results included in this report meet the recovery and precision requirements established by the AIHA, unless specifically indicated otherwise in the comment section.

ACCREDITATIONS: AIHA Environmental Lead Laboratory Approval Program #102561