

EMSL Analytical, Inc.

307 West 39th Street, New York, NY 10018

Phone: (212) 290-0051 Fax: (212) 290-0058 Email: manhattanlab@emsl.com

Attn: TRC Environmental Consultants
1430 Broadway
10th Floor
New York, NY 10018

Fax: (212) 221-7840

Phone: 212-221-7822

Project: 35052-0000-00017 / New York City Law Department / 100
Church St.

Customer ID: TRCE51

Customer PO:


Received: 03/04/03 5:11 PM

EMSL Order: 030303406

EMSL Project ID:

Lead in Wipes by Flame AAS (SW 846, 7420)

Client Sample Description	Lab ID	Analyzed	Area Sampled	Lead Concentration
ZD030403LW2001 20th Floor East Section - Center of South	0001	3/4/03	144 in ²	<10.0 µg/ft ²
ZD030403LW2002 20th Floor East Section - Center of East	0002	3/4/03	144 in ²	<10.0 µg/ft ²


Laboratory Manager
or other approved signatory

Reporting limit is 10 µg/wipe. The QC data associated with the sample results included in this report meet the recovery and precision requirements established by the AIHA, unless specifically indicated otherwise in the comment section.

ACCREDITATIONS: AIHA Environmental Lead Laboratory Approval Program #102581