

EMSL Analytical, Inc.

307 West 38th Street, New York, NY 10018

Phone: (212) 290-0051 Fax: (212) 290-0058 Email: manhattanlab@emsl.com

EMSL

Attn: TRC Environmental Consultants
1430 Broadway
10th Floor
New York, NY 10018

Fax: (212) 221-7840

Phone: 212-221-7822

Project: 35052-0000-00017 / New York City Law Department / 100
Church / Ambient

Customer ID: TRCE51

Customer PO:

Received: 03/15/03 10:52 AM

EMSL Order: 030304173

EMSL Project ID:


Analysis Date: 3/15/2003

Phase Contrast Microscopy (PCM) Fiber Count by NIOSH 7400, Fourth Edition, Issue 2,
8/15/94

Sample	Location	Sample Date	Volume	Fibers	Fields	LOD (fib/cc)	Fibers/ mm ²	Fibers/ cc	Notes
ZD031403ASBAI R2001	20th Center of North Side	3/15/2003	1527.02	<5.5	100	0.002	<7.0	<0.002	
030304173-0001									
ZD031403ASBAI R2002	20th Center of East Side	3/15/2003	1533.33	<5.5	100	0.002	<7.0	<0.002	
030304173-0002									
ZD031403ASBAI R2003	20th Floor Center of North Side	3/15/2003	1533.33	<5.5	100	0.002	<7.0	<0.002	
030304173-0003									
ZD031403ASBAI R2004	20th Floor Center of East Side	3/15/2003	1539.64	<5.5	100	0.002	<7.0	<0.002	
030304173-0004									
ZD031403ASBAI R2005	20th Floor Center of North Side	3/15/2003	1533.33	<5.5	100	0.002	<7.0	<0.002	
030304173-0005									
ZD031403ASBAI R2006	20th Floor Center of East Side	3/15/2003	1539.64	<5.5	100	0.002	<7.0	<0.002	
030304173-0006									
ZD031403ASBAI RFB01	Blank	3/15/2003	0.00	<5.5	100		<7.0		Field Blank
030304173-0007									

George Bobie

Analyst



Laboratory Manager
or other approved signatory

Limit of detection is 7 fibers/mm². The laboratory is not responsible for data reported in fibers/cc, which is dependent on volume collected by non-laboratory personnel. This report relates only to the samples reported above. This report may not be reproduced, except in full, without written approval by EMSL.
Analysis performed by EMSL Manhattan (NY State ELAP #11506, AHA #102581)

PCM-2

1

CITY_21MC100_012558215