

EMSL Analytical, Inc.

307 West 38th Street, New York, NY 10018

Phone: (212) 290-0051 Fax: (212) 290-0058 Email: manhattanlab@emsl.com



Attn: TRC Environmental Consultants
1430 Broadway
10th Floor
New York, NY 10018

Fax: (212) 221-7840

Phone: 212-221-7822

Project: 35052-0000-00017 / New York City Law Department /
Ambient

Customer ID: TRCE51

Customer PO:

Received: 03/23/03 9:49 PM

EMSL Order: 030304739

EMSL Project ID:

Analysis Date: 3/24/03

Phase Contrast Microscopy (PCM) Fiber Count by NIOSH 7400, Fourth Edition, Issue 2, 8/15/94

Sample	Location	Sample Date	Volume	Fibers	Fields	LOD (fib/cc)	Fibers/ mm ²	Fibers/ cc	Notes
ZD032303ASBAI R2001 030304739-0001	20th Floor N.W. Side	3/23/03	1539.64	7.0	100	0.002	8.92	0.002	
ZD032303ASBAI R2002 030304739-0002	20th Floor N.E. Side	3/23/03	1545.95	<5.5	100	0.002	<7.0	<0.002	
ZD032303ASBAI R2003 030304739-0003	20th Floor N.W. Side	3/23/03	1527.02	<5.5	100	0.002	<7.0	<0.002	
ZD032303ASBAI R2004 030304739-0004	20th Floor N.E. Side	3/23/03	1514.40	6.0	100	0.002	7.64	0.002	
ZD032303ASBAI R2005 030304739-0005	20th Floor N.W. Side	3/23/03	1533.33	10.0	100	0.002	12.74	0.003	
ZD032303ASBAI R2006 030304739-0006	20th Floor N.E. Side	3/23/03	1527.02	7.0	100	0.002	8.92	0.002	
ZD032303ASBAI RF201 030304739-0007	Field Blank	3/23/03	0.00	<5.5	100		<7.0		Field Blank

Mike Mengason

Analyst

Laboratory Manager
or other approved signatory

Limit of detection is 7 fibers/mm². The laboratory is not responsible for data reported in fibers/cc, which is dependent on volume collected by non-laboratory personnel. This report relates only to the samples reported above. This report may not be reproduced, except in full, without written approval by EMSL.
Analysis performed by EMSL Manhattan (NY State ELAP #11506, AHA #102861)

FUM-2

1