

EMSL Analytical, Inc.

307 West 38th Street, New York, NY 10018

Phone: (212) 290-0051 Fax: (212) 290-0052 Email: manhattanlab@emsl.com

Attn: TRC Environmental Consultants
1430 Broadway
10th Floor
New York, NY 10018

Fax: (212) 221-7840

Phone: 212-221-7822

Project: NEW YORK CITY LAW DEPT. / 100 CHURCH ST./
PROJECT NO. 35052-0000-00017

Customer ID: TRCE51

Customer PO:

Received: 03/22/03 11:06 PM

EMSL Order: 030304695

EMSL Project ID:

Lead in Air by Flame AAS (NIOSH 7082)

Client Sample Description	Lab ID	Analyzed	Volume	Lead Concentration
ZD032203LAIR2001 20TH Floor - N/W Side	0001	3/23/03	957.42 L	<4.2 µg/m³
ZD032203LAIR2002 20TH FLOOR - N/E SIDE	0002	3/23/03	961.36 L	<4.2 µg/m³
ZD032203LAIR2003 20TH FLOOR- N/W SIDE	0003	3/23/03	951.42 L	<4.2 µg/m³
ZD032203LAIR2004 20TH FLOOR - N/E SIDE	0004	3/23/03	951.42 L	<4.2 µg/m³
ZD032203LAIR2005 20TH FLOOR - NW SIDE	0005	3/23/03	1197.76 L	<3.3 µg/m³
ZD032203LAIR2006 20TH FLOOR - N/E SIDE	0006	3/23/03	1197.76 L	<3.3 µg/m³
ZD032203LAIRFB01 Blank	0007	3/23/03	n/a	<4.0 µg/filter

Laboratory Manager
or other approved signatory

Reporting limit is 4 µg/filter. The QC data associated with the sample results included in this report meet the recovery and precision requirements established by the AIHA, unless specifically indicated otherwise in the comment section. The laboratory is not responsible for data reported in µg/cc which is dependent on volume collected by non-laboratory personnel. This report may not be reproduced except in full, without written approval by EMSL.

ACCREDITATIONS: AIHA Environmental Lead Laboratory Approval Program #102581