

EMSL Analytical, Inc.

307 West 38th Street, New York, NY 10018

Phone: (212) 290-0051 Fax: (212) 290-0058 Email: manhattanlab@emsl.com

EMSL

Attn: TRC Environmental Consultants
1430 Broadway
10th Floor

New York, NY 10018

Fax: (212) 221-7840

Phone: 212-221-7822

Project: 35052-0000-00017 / New York City Law Department / 100
Church St. / Ambient

Customer ID: TRCE51

Customer PO:

Received: 03/29/03 10:05 PM

EMSL Order: 030305244

EMSL Project ID:


Analysis Date: 3/30/03

Phase Contrast Microscopy (PCM) Fiber Count by NIOSH 7400, Fourth Edition, Issue 2,
8/15/94

Sample	Location	Sample Date	Volume	Fibers	Fields	LOD (fib/cc)	Fibers/ mm ³	Fibers/ cc	Notes
ZD032903ASBAI R2001 030305244-0001	20th Floor Center of East Side	3/29/03	1533.33	<5.5	100	0.002	<7.0	<0.002	
ZD032903ASBAI R2002 030305244-0002	20th Floor Center of West Side	3/29/03	1539.64	10.5	100	0.002	13.38	0.003	
ZD032903ASBAI R2003 030305244-0003	20th Floor Center of East Side	3/29/03	1527.02	15.5	100	0.002	19.75	0.005	
ZD032903ASBAI R2004 030305244-0004	20th Floor Center of West Side	3/29/03	1533.33	<5.5	100	0.002	<7.0	<0.002	
ZD032903ASBAI R2005 030305244-0005	20th Floor Center of East Side	3/29/03	1533.33	<5.5	100	0.002	<7.0	<0.002	
ZD032903ASBAI R2006 030305244-0006	20th Floor Center of West Side	3/29/03	1527.02	<5.5	100	0.002	<7.0	<0.002	
ZD032903ASBAI RFB01 030305244-0007	Blank	3/29/03	0.00	<5.5	100		<7.0		Field Blank

Jose Arriaga

Analyst


Laboratory Manager
or other approved signatory

Limit of detection is 7 fibers/mm³. The laboratory is not responsible for data reported in fibers/cc, which is dependent on volume collected by non-laboratory personnel. This report relates only to the samples reported above. This report may not be reproduced, except in full, without written approval by EMSL.
Analysis performed by EMSL Manhattan (NY State ELAP #11508, AIPA #102581)

PCM 2

1